

CERTIFICATE OF ANALYSIS

Client: YALE School  
10-A Jennings Road  
Medford NJ 08055  
Client: YAL001

Report Date: 12/30/2021  
Report No.: 649876 - Lead Water  
Project: West II  
Project No.:

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7336759      Location: 1st Fl Restroom      Result(ppb): 2.40  
Client No.: 1      \* Sample acidified to pH <2.

Lab No.: 7336760      Location: 1st Fl Boy's B/R      Result(ppb): 1.40  
Client No.: 2      \* Sample acidified to pH <2.

Lab No.: 7336761      Location: 1st Fl D/F (Next To Back Door)      Result(ppb): <1.00  
Client No.: 3      \* Sample acidified to pH <2.

Lab No.: 7336762      Location: 1st Fl D/F (Next To B/R)      Result(ppb): <1.00  
Client No.: 4      \* Sample acidified to pH <2.

Lab No.: 7336763      Location: 2nd Fl D/F      Result(ppb): <1.00  
Client No.: 5      \* Sample acidified to pH <2.

Lab No.: 7336764      Location: 2nd Fl Boy's B/R      Result(ppb): 9.50  
Client No.: 6      \* Sample acidified to pH <2.

Lab No.: 7336765      Location: 2nd Fl Girl's B/R      Result(ppb): 3.80  
Client No.: 7      \* Sample acidified to pH <2.

Lab No.: 7336766      Location: 2nd Fl Staff B/R      Result(ppb): 7.00  
Client No.: 8      \* Sample acidified to pH <2.

Lab No.: 7336767      Location: Wood Shop Sink      Result(ppb): 2.70  
Client No.: 9      \* Sample acidified to pH <2.


Lab No.: 7336768      Location: Kitchen Sink      Result(ppb): 2.60  
Client No.: 10      \* Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 12/28/2021

Date Analyzed: 12/30/2021

Signature:   
Analyst: Mark Stewart

Approved By:   
Frank E. Ehrenfeld, III  
Laboratory Director



9000 Commerce Parkway Suite B  
Mt. Laurel, New Jersey 08054  
Telephone: 856-231-9449  
Email: customerservice@iatl.com

CERTIFICATE OF ANALYSIS

Client: YALE School  
10-A Jennings Road  
Medford NJ 08055  
Client: YAL001

Report Date: 12/30/2021  
Report No.: 649876 - Lead Water  
Project: West II  
Project No.:

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:7336769  
Client No.:11

Location: 1st Fl Girl's B/R  
\* Sample acidified to pH <2.

Result(ppb):<1.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 12/28/2021  
Date Analyzed: 12/30/2021  
Signature:   
Analyst: Mark Stewart

Approved By:   
Frank E. Ehrenfeld, III  
Laboratory Director



9000 Commerce Parkway Suite B  
Mt. Laurel, New Jersey 08054  
Telephone: 856-231-9449  
Email: customerservice@iatl.com

## CERTIFICATE OF ANALYSIS

Client: YALE School  
10-A Jennings Road  
Medford NJ 08055

Client: YAL001

Report Date: 12/30/2021  
Report No.: 649876 - Lead Water  
Project: West II  
Project No.:

## Appendix to Analytical Report:

**Customer Contact:** Scott Klenk  
**Analysis:** AAS-GF - ASTM D3559-08D

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

**IATL Customer Service:** customerservice@iatl.com  
**IATL Office Manager:** ?wchampion@iatl.com  
**IATL Account Representative:** Kelly Klippel  
**Sample Login Notes:** See Batch Sheet Attached  
**Sample Matrix:** Water  
**Exceptions Noted:** See Following Pages

### **General Terms, Warrants, Limits, Qualifiers:**

General information about IATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at [www.iATL.com](http://www.iATL.com) and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

### **Information Pertinent to this Report:**

Analysis by AAS Graphite Furnace:  
- ASTM D3559-08D

#### **Certification:**

- NYS-DOH No. 11021  
- NJDEP No. 03863

### **Note: These methods are analytically equivalent to iATL's accredited method;**

- USEPA 40CFR 141.11B  
- USEPA 200.9 Pb, AAS-GF, RL <2 ppb/sample  
- USEPA SW 846-7421 - Pb(AAS-GF, RL <2 ppb/sample)

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 1.0 PPB



9000 Commerce Parkway Suite B  
Mt. Laurel, New Jersey 08054  
Telephone: 856-231-9449  
Email: customerservice@iatl.com

---

CERTIFICATE OF ANALYSIS

---

Client: YALE School  
10-A Jennings Road  
Medford NJ 08055

Client: YAL001

Report Date: 12/30/2021  
Report No.: 649876 - Lead Water  
Project: West II  
Project No.:

**Disclaimers / Qualifiers:**

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at [customerservice@iatl.com](mailto:customerservice@iatl.com).

Matrix spiking is performed on each client batch to determine if interferences could impact results. When spike recoveries fall out of acceptable range matrix interference is suspected and samples are diluted until acceptable spike recovery can be achieved. Reporting limits will increase by the same degree as the dilution required.

Note: Sample dilution required due to matrix interference.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

\* ASTM D3559 (D) calls for the addition of acid at the time of sampling. Unless so noted on the chain of custody by the client IATL acidifies samples to a pH of <2 at least 24 hours prior to analysis.