

NJ Department of Education

www.nj.gov/education/lead/
leadtesting@doe.state.nj.us



School District Lead Sampling Program Checklist

SCHOOL DISTRICT INFORMATION

District Name:

Audubon

Address:

350 Edgewood Ave., Audubon, NJ 08106

Telephone number:

856-547-7695

Application Signatory:

Rafael V. Velez

Note: Any sampling done prior to July 13, 2011 is not eligible for exemption from State Board of Education Special Adopted Amendments N.J.A.C. 6A:26-1.2 and 12.4.

COMPLETION OF INITIAL LEAD SAMPLING AT 3 SCHOOL FACILITIES OUT OF 3 SCHOOL FACILITIES

Fill out the table below for each school facility the School District has completed initial lead sampling. Make as many copies of the following page as necessary.

School Facility Name

Mansion Ave., School

Sampling Date(s)

4/19/17

Yes [] No ☒

Does the District have a signed contract with a New Jersey Certified Drinking Water Laboratory for lead analysis?

Yes [] No ☒

Is there a Plumbing Profile in accordance with NJDEP technical guidance?

Yes ☒ No []

Is there a Floor Plan in accordance with NJDEP technical guidance?

Yes ☒ No []

Were all the drinking water outlets in the school facility (including auxiliary buildings and outside outlets on the school grounds) where a student or staff member has or may have access sampled?

Yes ☒ No []

Were all the drinking water outlets sampled in the sequence determined by the Floor Plan beginning with the outlet closest to the Point of Entry?

Yes ☒ No []

Were all samples taken after the water sat undisturbed in pipes for at least 8 hours but no more than 48 hours?

Yes ☒ No []

Were samples collected in pre-cleaned high density polyethylene (HDPE) 250 ml wide mouth single use rigid sample containers?

Yes ☒ No []

Were all existing aerators, screens, and filters left in place prior to and during the sampling event?

Yes ☒ No [] N/A []

Were all drinking water outlets with a result exceeding the lead action level (15µg/L) taken out of service or permanently remediated?

Yes [] No ☒ N/A []

Did all drinking water outlets with a result that exceeded the lead action level (15µg/L) have a follow-up flush sample conducted?

Yes ☒ No []

Does the District have the Chains of Custody and analytical reports for all of the drinking water outlets sampled?

Yes ☒ No []

Were test results of all water samples made publicly available at the school facility and on the District's website?

Yes [] No ☒ N/A []

If any of the results exceeded the lead action level (15µg/L), was written notification sent to the parent/guardians of all students attending the facility?



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Tom Pruno
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109**

5/8/2017

Phone: (856) 616-9516
Fax: (586) 616-9517

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 4/24/2017. The results are tabulated on the attached data pages for the following client designated project:

Audubon BOE - Manison Ave School / PR-161215-1209

The reference number for these samples is EMSL Order #011703128. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.



Environmental Design Inc.

Professional Environmental Consultants

Lead (Pb) in Water Sampling Chain of Custody

EMSL Order ID (Lab Use Only):

Company:	Environmental Design Inc. (EDI-50)	EMSL Bill To:	EDI-50
Street:	5434 King Avenue, Suite 101	Phone:	856-616-9516
City/State/Zip:	Pennsauken, NJ 08109	Fax:	856-616-9519
Send Report To:	Tom Pruno	Send Results To:	tp@editesting.com
State Samples Taken:	NJ	Turnaround Time (TAT):	2 Weeks

Matrix	Method	Instrument	Reporting Limit	Preservative
Drinking Water (Preserved w/HNO ₃ pH <2)	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	Nitric acid
EDI Client/Site: Audubon BOE- Mansion Ave School EDI Project #: PR-161215-1209				
** SPECIAL INSTRUCTIONS** Please provide standard report as well as an Excel Data File				

Sample #	Sample Description/Location	Volume	Date/Time Sampled
38-0419-M01	Rm 145 Art Rm - Middle Sink	250 mL	4/19/2017 11:12 AM
38-0419-M02	Boys Restroom across from 135-1st one	250 mL	4/19/2017 11:16 AM
38-0419-M03	Water Fountain across from Rm 132-left side	250 mL	4/19/2017 11:17 AM
38-0419-M04	Water Fountain across from Rm 132-right side	250 mL	4/19/2017 11:18 AM
38-0419-M05	Girls Restroom across from Rm 130-1st one	250 mL	4/19/2017 11:19 AM
38-0419-M06	Boys Restroom sink next to main office-1st one	250 mL	4/19/2017 11:20 AM
38-0419-M07	Water Fountain across from main office	250 mL	4/19/2017 11:21 AM
38-0419-M08	Girls Restroom Sink near main office -1st one	250 mL	4/19/2017 11:22 AM
38-0419-M09	Rm 153 Water Fountain	250 mL	4/19/2017 11:24 AM
38-0419-M10	Rm 152 Sink	250 mL	4/19/2017 11:25 AM
38-0419-M11	Rm 150 Water Fountain	250 mL	4/19/2017 11:25 AM
38-0419-M12	Rm 117 Sink	250 mL	4/19/2017 11:26 AM

Relinquished By: Randi Wheeler		Received By:	
Date: 4/24/17	Time:	Date:	Time:
Sampler: Randi Wheeler		Total Samples: 35	Page: 1 of 3



EDI is a Service Disabled Veteran Owned Small Business!



Lead (Pb) in Water Sampling Chain of Custody

EMSL Order ID (Lab Use Only):

Company:	Environmental Design Inc. (EDI-50)	EMSL Bill To:	EDI-50
Street:	5434 King Avenue, Suite 101	Phone:	856-616-9516
City/State/Zip:	Pennsauken, NJ 08109	Fax:	856-616-9519
Send Report To:	Tom Pruno	Send Results To:	tp@editesting.com
State Samples Taken:	NJ	Turnaround Time (TAT):	2 Weeks

Matrix	Method	Instrument	Reporting Limit	Preservative
Drinking Water (Preserved w/HNO ₃ pH <2)	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	Nitric acid
EDI Client/Site: Audubon BOE- Mansion Ave School EDI Project #: PR-161215-1209				
** SPECIAL INSTRUCTIONS** Please provide standard report as well as an Excel Data File				

Sample #	Sample Description/Location	Volume	Date/Time Sampled
38-0419-M13	Rm 121 Nurse's Office Sink	250 mL	4/19/2017 11:27 AM
38-0419-M14	Women's Restroom Sink-across from Gym	250 mL	4/19/2017 11:30 AM
38-0419-M15	Men's Restroom Sink-across from Gym	250 mL	4/19/2017 11:30 AM
38-0419-M16	Rm 108A Classroom Sink	250 mL	4/19/2017 11:34 AM
38-0419-M17	Rm 108 Water Fountain	250 mL	4/19/2017 11:34 AM
38-0419-M18	Rm 98 Water Fountain	250 mL	4/19/2017 11:37 AM
38-0419-M19	Rm 99 Water Fountain	250 mL	4/19/2017 11:38 AM
38-0419-M20	Rm 159 Classroom Sink	250 mL	4/19/2017 11:40 AM
38-0419-M21	Kitchen Sink	250 mL	4/19/2017 11:40 AM
38-0419-M22	Girls Restroom Sink across from Rm 212	250 mL	4/19/2017 11:47 AM
38-0419-M23	Water Fountain near Rm 213	250 mL	4/19/2017 11:49 AM
38-0419-M24	Water Fountain across from Rm 214	250 mL	4/19/2017 11:49 AM

Relinquished By: Randi Wheeler	Received By:
Date: 4/24/17	Date:
Time:	Time:
Sampler: Randi Wheeler	Total Samples: 35
	Page: 2 of 3



EDI is a Service Disabled Veteran Owned Small Business!



Lead (Pb) in Water Sampling Chain of Custody

EMSL Order ID (Lab Use Only):

Company:	Environmental Design Inc. (EDI-50)	EMSL Bill To:	EDI-50
Street:	5434 King Avenue, Suite 101	Phone:	856-616-9516
City/State/Zip:	Pennsauken, NJ 08109	Fax:	856-616-9519
Send Report To:	Tom Pruno	Send Results To:	tp@editesting.com
State Samples Taken:	NJ	Turnaround Time (TAT):	2 Weeks

Matrix	Method	Instrument	Reporting Limit	Preservative
Drinking Water (Preserved w/HNO ₃ pH <2)	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	Nitric acid
EDI Client/Site: Audubon BOE- Mansion Ave School EDI Project #: PR-161215-1209				
** SPECIAL INSTRUCTIONS** Please provide standard report as well as an Excel Data File				

Sample #	Sample Description/Location	Volume	Date/Time Sampled
38-0419-M25	Water Fountain near Rm 215	250 mL	4/19/2017 11:50 AM
38-0419-M26	Boys Restroom Sink across from Rm 221	250 mL	4/19/2017 11:51 AM
38-0419-M27	Water Fountain next to Rm 224	250 mL	4/19/2017 11:52 AM
38-0419-M28	Girls Restroom Sink across from Rm 208	250 mL	4/19/2017 11:53 AM
38-0419-M29	Boys Restroom Sink across from Rm 207	250 mL	4/19/2017 11:55 AM
38-0419-M30	Water Fountain across from Rm 207	250 mL	4/19/2017 11:55 AM
38-0419-M31	Rm 206 Sink	250 mL	4/19/2017 11:57 AM
38-0419-M32	Water Fountain in Rm 204	250 mL	4/19/2017 11:58 AM
38-0419-M33	Rm 203 Sink	250 mL	4/19/2017 11:59 AM
38-0419-M34	Restroom Sink next to Rm 229A	250 mL	4/19/2017 12:00 PM
38-0419-M35	Water Fountain in Rm 202	250 mL	4/19/2017 12:02 PM

Relinquished By: Randi Wheeler	Received By:		
Date: 4/24/17	Time:	Date:	Time:
Sampler: Randi Wheeler	Total Samples: 35	Page: 3	of 3



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011703128

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 04/24/17 2:30 PM

Project: Audubon BOE - Manlson Ave School / PR-161215-1209

Analytical Results

Client Sample Description		38-0419-M01 Rm 145 Art Rm - Middle Sink	Collected:		4/19/2017	Lab ID:		011703128-0001
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.53	1.00	µg/L	5/1/2017	EG	5/1/2017	EG
Client Sample Description		38-0419-M02 Boys Restroom Across From 135-1st One	Collected:		4/19/2017	Lab ID:		011703128-0002
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.31	1.00	µg/L	5/1/2017	EG	5/1/2017	EG
Client Sample Description		38-0419-M03 Water Fountain Across From Rm 132- Left Side	Collected:		4/19/2017	Lab ID:		011703128-0003
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	5/1/2017	EG	5/1/2017	EG
Client Sample Description		38-0419-M04 Water Fountain Across From Rm 132- Right Side	Collected:		4/19/2017	Lab ID:		011703128-0004
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	5/1/2017	EG	5/1/2017	EG
Client Sample Description		38-0419-M05 Girls Restroom Across From Rm 130- 1st One	Collected:		4/19/2017	Lab ID:		011703128-0005
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.61	1.00	µg/L	5/1/2017	EG	5/1/2017	EG
Client Sample Description		38-0419-M06 Boys Restroom Sink Next To Main Office - 1st One	Collected:		4/19/2017	Lab ID:		011703128-0006
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	5/1/2017	EG	5/1/2017	EG
Client Sample Description		38-0419-M07 Water Fountain Across From Main Office	Collected:		4/19/2017	Lab ID:		011703128-0007
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	5/1/2017	EG	5/1/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011703128

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 04/24/17 2:30 PM

Project: Audubon BOE - Manison Ave School / PR-161215-1209

Analytical Results

Client Sample Description		38-0419-M08 Girls Restroom Sink Near Main Office - 1st One	Collected:	4/19/2017	Lab ID:	011703128-0008		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.61	1.00	µg/L	5/1/2017	EG	5/1/2017	EG
Client Sample Description		38-0419-M09 Rm 135 Water Fountain	Collected:	4/19/2017	Lab ID:	011703128-0009		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.97	1.00	µg/L	5/1/2017	EG	5/1/2017	EG
Client Sample Description		38-0419-M10 Rm 125 Sink	Collected:	4/19/2017	Lab ID:	011703128-0010		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.29	1.00	µg/L	5/1/2017	EG	5/1/2017	EG
Client Sample Description		38-0419-M11 Rm 150 Water Fountain	Collected:	4/19/2017	Lab ID:	011703128-0011		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.06	1.00	µg/L	5/1/2017	EG	5/1/2017	EG
Client Sample Description		38-0419-M12 Rm 117 Sink	Collected:	4/19/2017	Lab ID:	011703128-0012		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.49	1.00	µg/L	5/1/2017	EG	5/1/2017	EG
Client Sample Description		38-0419-M13 Rm 121 Nurse's Office Sink	Collected:	4/19/2017	Lab ID:	011703128-0013		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.93	1.00	µg/L	5/1/2017	EG	5/1/2017	EG
Client Sample Description		38-0419-M14 Women's Restroom Sink - Across From Gym	Collected:	4/19/2017	Lab ID:	011703128-0014		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.87	1.00	µg/L	5/1/2017	EG	5/1/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011703128

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 04/24/17 2:30 PM

Project: Audubon BOE - Manison Ave School / PR-161215-1209

Analytical Results

Client Sample Description		38-0419-M15 Men's Restroom Sink- Across From Gym	Collected:		4/19/2017	Lab ID:		011703128-0015	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	1.63	1.00	µg/L	5/1/2017	EG	5/1/2017	EG	
Client Sample Description		38-0419-M16 Rm 108A Classroom Sink	Collected:		4/19/2017	Lab ID:		011703128-0016	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	6.26	1.00	µg/L	5/1/2017	EG	5/1/2017	EG	
Client Sample Description		38-0419-M17 Rm 108 Water Fountain	Collected:		4/19/2017	Lab ID:		011703128-0017	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	3.28	1.00	µg/L	5/1/2017	EG	5/1/2017	EG	
Client Sample Description		38-0419-M18 Rm 98 Water Fountain	Collected:		4/19/2017	Lab ID:		011703128-0018	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	5/1/2017	EG	5/1/2017	EG	
Client Sample Description		38-0419-M19 Rm 99 Water Fountain	Collected:		4/19/2017	Lab ID:		011703128-0019	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	5/1/2017	EG	5/1/2017	EG	
Client Sample Description		38-0419-M20 Rm 159 Classroom Sink	Collected:		4/19/2017	Lab ID:		011703128-0020	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	5/1/2017	EG	5/1/2017	EG	
Client Sample Description		38-0419-M21 Kitchen Sink	Collected:		4/19/2017	Lab ID:		011703128-0021	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	5/8/2017	EG	5/8/2017	EG	
Client Sample Description		38-0419-M22 Girls Restroom Sink Across From Rm 212	Collected:		4/19/2017	Lab ID:		011703128-0022	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011703128

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 04/24/17 2:30 PM

Project: Audubon BOE - Manison Ave School / PR-161215-1209

Analytical Results

Client Sample Description			38-0419-M22 Girls Restroom Sink Across From Rm 212		Collected:	4/19/2017	Lab ID:	011703128-0022	
Method	Parameter	Result	RL	Units		Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.65	1.00	µg/L		5/8/2017	EG	5/8/2017	EG
Client Sample Description			38-0419-M23 Water Fountain Near Rm 213		Collected:	4/19/2017	Lab ID:	011703128-0023	
Method	Parameter	Result	RL	Units		Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L		5/8/2017	EG	5/8/2017	EG
Client Sample Description			38-0419-M24 Water Fountain Across From Rm 214		Collected:	4/19/2017	Lab ID:	011703128-0024	
Method	Parameter	Result	RL	Units		Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L		5/8/2017	EG	5/8/2017	EG
Client Sample Description			38-0419-M25 Water Fountain Near Rm 215		Collected:	4/19/2017	Lab ID:	011703128-0025	
Method	Parameter	Result	RL	Units		Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L		5/8/2017	EG	5/8/2017	EG
Client Sample Description			38-0419-M26 Boys Restroom Sink Across From Rm 221		Collected:	4/19/2017	Lab ID:	011703128-0026	
Method	Parameter	Result	RL	Units		Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.77	1.00	µg/L		5/8/2017	EG	5/8/2017	EG
Client Sample Description			38-0419-M27 Water Fountain Nect To Rm 224		Collected:	4/19/2017	Lab ID:	011703128-0027	
Method	Parameter	Result	RL	Units		Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.08	1.00	µg/L		5/8/2017	EG	5/8/2017	EG
Client Sample Description			38-0419-M28 Girls Restroom Sink Across From Rm 208		Collected:	4/19/2017	Lab ID:	011703128-0028	
Method	Parameter	Result	RL	Units		Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.07	1.00	µg/L		5/8/2017	EG	5/8/2017	EG
Client Sample Description			38-0419-M29 Boys Restroom Sink Across From Rm 207		Collected:	4/19/2017	Lab ID:	011703128-0029	
Method	Parameter	Result	RL	Units		Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011703128

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 04/24/17 2:30 PM

Project: Audubon BOE - Manison Ave School / PR-161215-1209

Analytical Results

Client Sample Description		38-0419-M29 Boys Restroom Sink Across From Rm 207	Collected:	4/19/2017	Lab ID:	011703128-0029		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.41	1.00	µg/L	5/8/2017	EG	5/8/2017	EG
Client Sample Description		38-0419-M30 Water Fountain Across From Rm 207	Collected:	4/19/2017	Lab ID:	011703128-0030		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	16.4	1.00	µg/L	5/8/2017	EG	5/8/2017	EG
Client Sample Description		38-0419-M31 Rom 206 Sink	Collected:	4/19/2017	Lab ID:	011703128-0031		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.31	1.00	µg/L	5/1/2017	EG	5/1/2017	EG
Client Sample Description		38-0419-M32 Water Fountain In Rm 204	Collected:	4/19/2017	Lab ID:	011703128-0032		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.49	1.00	µg/L	5/1/2017	EG	5/1/2017	EG
Client Sample Description		38-0419-M33 Rm 203 Sink	Collected:	4/19/2017	Lab ID:	011703128-0033		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	45.7	1.00	µg/L	5/1/2017	EG	5/1/2017	EG
Client Sample Description		38-0419-M34 Restroom Sink Nect To Rm 229A	Collected:	4/19/2017	Lab ID:	011703128-0034		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	5/1/2017	EG	5/1/2017	EG
Client Sample Description		38-0419-M35 Water Fountain In Rm 202	Collected:	4/19/2017	Lab ID:	011703128-0035		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.93	1.00	µg/L	5/1/2017	EG	5/1/2017	EG

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

Attachment L - Lead in Water Sample Results Summary

School Name: Audubon BOE - Mansion Ave School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
1S	38-0419-M01	Rm 145 Art Rm - Middle Sink	9.53	No
2S	38-0419-M02	Boys Restroom across from 135-1st one	2.31	No
3WF	38-0419-M03	Water Fountan across from Rm 132-left side	ND	No
4WF	38-0419-M04	Water Fountan across from Rm 132-right side	ND	No
5S	38-0419-M05	Girls Restroom across from Rm 130-1st one	2.61	No
6S	38-0419-M06	Boys Restroom sink next to main office-1st one	ND	No
7WF	38-0419-M07	Water Fountain across from main office	ND	No
8S	38-0419-M08	Girls Restroom Sink near main office -1st one	1.61	No
9WF	38-0419-M09	Rm 153 Water Fountain	1.97	No
10S	38-0419-M10	Rm 152 Sink	1.29	No
11WF	38-0419-M11	Rm 150 Water Fountain	2.06	No
12S	38-0419-M12	Rm 117 Sink	5.49	No
13S	38-0419-M13	Rm 121 Nurse's Office Sink	1.93	No
14S	38-0419-M14	Women's Restroom Sink-across from Gym	3.87	No
15S	38-0419-M15	Men's Restroom Sink-across from Gym	1.63	No
16S	38-0419-M16	Rm 108A Classroom Sink	6.26	No
17WF	38-0419-M17	Rm 108 Water Fountain	3.28	No
18WF	38-0419-M18	Rm 98 Water Fountain	ND	No
19WF	38-0419-M19	Rm 99 Water Fountain	ND	No
20S	38-0419-M20	Rm 159 Classroom Sink	ND	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)

Attachment L - Lead in Water Sample Results Summary

School Name: Audubon BOE - Mansion Ave School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
21S	38-0419-M21	Kitchen Sink	ND	No
22S	38-0419-M22	Girls Restroom Sink across from Rm 212	1.65	No
23WF	38-0419-M23	Water Fountain near Rm 213	ND	No
24WF	38-0419-M24	Water Fountain across from Rm 214	ND	No
25WF	38-0419-M25	Water Fountain near Rm 215	ND	No
26S	38-0419-M26	Boys Restroom Sink across from Rm 221	7.77	No
27WF	38-0419-M27	Water Fountain next to Rm 224	2.08	No
28S	38-0419-M28	Girls Restroom Sink across from Rm 208	1.07	No
29S	38-0419-M29	Boys Restroom Sink across from Rm 207	4.41	No
30WF	38-0419-M30	Water Fountain across from Rm 207	16.40	Yes
31S	38-0419-M31	Rm 206 Sink	8.31	No
32 WF	38-0419-M32	Water Fountain in Rm 204	1.49	No
33S	38-0419-M33	Rm 203 Sink	45.70	Yes
34S	38-0419-M34	Restroom Sink next to Rm 229A	ND	No
35WF	38-0419-M35	Water Fountain in Rm 202	1.93	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)