

Building: Evans Elementary School Lead Results - 2025

Sample Location	Date Collected	Time Collected	Flushed	Result	Lead Action Level	Analytical Method	Date of Analysis
			(Y/N)	(ug/L)	(ug/L)		
121 Hall Drinking Fountain	2/19/2025	4:49AM	N	10.1	15.0	EPA 200.8	2/25/2025
121 Lunch Room Sinks- 1	2/19/2025	4:50AM	N	5.7	15.0	EPA 200.8	2/25/2025
121 Lunch Room Sinks- 2	2/19/2025	4:51AM	N	12.9	15.0	EPA 200.8	2/25/2025
119 Drinking Fountain	2/19/2025	4:53AM	N	<1.0	15.0	EPA 200.8	2/25/2025
213 Hall Water Cooler -1	2/19/2025	4:55AM	N	<1.0	15.0	EPA 200.8	2/25/2025
213 Hall Water Cooler -2	2/19/2025	4:56AM	N	<1.0	15.0	EPA 200.8	2/25/2025
140 Hall Drinking Fountain	2/19/2025	5:00AM	N	3.7	15.0	EPA 200.8	2/25/2025
141 Nurse Drinking Fountain	2/19/2025	5:04AM	N	4.4	15.0	EPA 200.8	2/25/2025
142 Drinking Fountain	2/19/2025	5:09AM	N	1.5	15.0	EPA 200.8	2/25/2025
216 Hall Water Cooler -1	2/19/2025	5:11AM	N	<1.0	15.0	EPA 200.8	2/25/2025
149 Drinking Fountain	2/19/2025	5:14AM	N	<1.0	15.0	EPA 200.8	2/25/2025
152 Drinking Fountain	2/19/2025	5:16AM	N	93.0	15.0	EPA 200.8	2/25/2025
152 Drinking Fountain- FLUSH	2/28/2025	10:45AM	Y	<1.0	15.0	EPA 200.8	3/7/2025
150 Drinking Fountain	2/19/2025	5:18AM	N	<1.0	15.0	EPA 200.8	2/25/2025
151 Drinking Fountain	2/19/2025	5:21AM	N	<1.0	15.0	EPA 200.8	2/25/2025
217 Hall Drinking Fountain- 1	2/19/2025	5:23AM	N	2.4	15.0	EPA 200.8	2/25/2025
217 Hall Drinking Fountain - 2	2/19/2025	5:32AM	N	4.30	15.0	EPA 200.8	2/25/2025
217 Hall Drinking Fountain - 3	2/19/2025	5:34AM	N	9.8	15.0	EPA 200.8	2/25/2025

Sample Location	Date Collected	Time Collected	Flushed	Result	Lead Action Level	Analytical Method	Date of Analysis
			(Y/N)	(ug/L)	(ug/L)		
200 Kitchen Sink - 1	2/19/2025	5:39AM	N	<1.0	15.0	EPA 200.8	2/27/2025
200 Kitchen Sink - 2	2/19/2025	5:40AM	N	1.5	15.0	EPA 200.8	2/27/2025
200 Kitchen Sink - 3	2/19/2025	5:42AM	N	4.9	15.0	EPA 200.8	2/27/2025
204 Room Water Cooler	2/19/2025	5:46AM	N	<1.0	15.0	EPA 200.8	2/27/2025
218 Hall Drinking Fountain - 1	2/19/2025	5:48AM	N	4.0	15.0	EPA 200.8	2/27/2025
218 Hall Drinking Fountain - 2	2/19/2025	5:49AM	N	8.2	15.0	EPA 200.8	2/27/2025
169 Drinking Fountain	2/19/2025	5:51AM	N	1.9	15.0	EPA 200.8	2/28/2025
176 Kitchen Sink	2/19/2025	5:54AM	N	1.6	15.0	EPA 200.8	2/28/2025
110 Drinking Fountain	2/19/2025	5:57AM	N	5.4	15.0	EPA 200.8	2/28/2025
112 Drinking Fountain	2/19/2025	5:59AM	N	1.4	15.0	EPA 200.8	2/28/2025
113 Drinking Fountain	2/19/2025	6:02AM	N	11.0	15.0	EPA 200.8	2/28/2025
115 Drinking Fountain	2/19/2025	6:03AM	N	4.8	15.0	EPA 200.8	2/28/2025
114 Drinking Fountain	2/19/2025	6:05AM	N	8.8	15.0	EPA 200.8	2/28/2025
109 Nurses Sink	2/19/2025	6:08AM	N	<1.0	15.0	EPA 200.8	2/28/2025
109 Water Cooler	2/19/2025	6:09AM	N	1.8	15.0	EPA 200.8	2/28/2025

Building: Evans Elementary School Lead Results - 2025

Sample Location	Date Collected	Time Collected	Flushed	Result	Lead Action Level	Analytical Method	Date of Analysis
					(ug/L)		
			(Y/N)	(ug/L)	(ug/L)		
121 Hall Drinking Fountain	2/19/2025	4:49AM	N	10.1	15.0	EPA 200.8	2/25/2025
121 Lunch Room Sinks- 1	2/19/2025	4:50AM	N	5.7	15.0	EPA 200.8	2/25/2025
121 Lunch Room Sinks- 2	2/19/2025	4:51AM	N	12.9	15.0	EPA 200.8	2/25/2025
119 Drinking Fountain	2/19/2025	4:53AM	N	<1.0	15.0	EPA 200.8	2/25/2025
213 Hall Water Cooler -1	2/19/2025	4:55AM	N	<1.0	15.0	EPA 200.8	2/25/2025
213 Hall Water Cooler -2	2/19/2025	4:56AM	N	<1.0	15.0	EPA 200.8	2/25/2025
140 Hall Drinking Fountain	2/19/2025	5:00AM	N	3.7	15.0	EPA 200.8	2/25/2025
141 Nurse Drinking Fountain	2/19/2025	5:04AM	N	4.4	15.0	EPA 200.8	2/25/2025
142 Drinking Fountain	2/19/2025	5:09AM	N	1.5	15.0	EPA 200.8	2/25/2025
216 Hall Water Cooler -1	2/19/2025	5:11AM	N	<1.0	15.0	EPA 200.8	2/25/2025
149 Drinking Fountain	2/19/2025	5:14AM	N	<1.0	15.0	EPA 200.8	2/25/2025
152 Drinking Fountain	2/19/2025	5:16AM	N	93.0	15.0	EPA 200.8	2/25/2025
150 Drinking Fountain	2/19/2025	5:18AM	N	<1.0	15.0	EPA 200.8	2/25/2025
151 Drinking Fountain	2/19/2025	5:21AM	N	<1.0	15.0	EPA 200.8	2/25/2025
217 Hall Drinking Fountain- 1	2/19/2025	5:23AM	N	2.4	15.0	EPA 200.8	2/25/2025
217 Hall Drinking Fountain - 2	2/19/2025	5:32AM	N	4.30	15.0	EPA 200.8	2/25/2025
217 Hall Drinking Fountain - 3	2/19/2025	5:34AM	N	9.8	15.0	EPA 200.8	2/25/2025

200 Kitchen Sink - 1	2/19/2025	5:39AM	N	<1.0	15.0	EPA 200.8	2/27/2025
200 Kitchen Sink - 2	2/19/2025	5:40AM	N	1.5	15.0	EPA 200.8	2/27/2025
200 Kitchen Sink - 3	2/19/2025	5:42AM	N	4.9	15.0	EPA 200.8	2/27/2025
204 Room Water Cooler	2/19/2025	5:46AM	N	<1.0	15.0	EPA 200.8	2/27/2025
218 Hall Drinking Fountain - 1	2/19/2025	5:48AM	N	4.0	15.0	EPA 200.8	2/27/2025
218 Hall Drinking Fountain - 2	2/19/2025	5:49AM	N	8.2	15.0	EPA 200.8	2/27/2025
169 Drinking Fountain	2/19/2025	5:51AM	N	1.9	15.0	EPA 200.8	2/28/2025
176 Kitchen Sink	2/19/2025	5:54AM	N	1.6	15.0	EPA 200.8	2/28/2025
110 Drinking Fountain	2/19/2025	5:57AM	N	5.4	15.0	EPA 200.8	2/28/2025
112 Drinking Fountain	2/19/2025	5:59AM	N	1.4	15.0	EPA 200.8	2/28/2025
113 Drinking Fountain	2/19/2025	6:02AM	N	11.0	15.0	EPA 200.8	2/28/2025
115 Drinking Fountain	2/19/2025	6:03AM	N	4.8	15.0	EPA 200.8	2/28/2025
114 Drinking Fountain	2/19/2025	6:05AM	N	8.8	15.0	EPA 200.8	2/28/2025
109 Nurses Sink	2/19/2025	6:08AM	N	<1.0	15.0	EPA 200.8	2/28/2025
109 Water Cooler	2/19/2025	6:09AM	N	1.8	15.0	EPA 200.8	2/28/2025

Building: Evans Elementary School Lead Results - 2025

Sample Location	Date Collected	Time Collected	Flushed	Result	Reporting Limit	Analytical Method	Date of Analysis
			(Y/N)	(ug/L)	(ug/L)		
121 Hall Drinking Fountain	2/19/2025	4:49AM	N	10.1	1.0	EPA 200.8	2/25/2025
121 Lunch Room Sinks- 1	2/19/2025	4:50AM	N	5.7	1.0	EPA 200.8	2/25/2025
121 Lunch Room Sinks- 2	2/19/2025	4:51AM	N	12.9	1.0	EPA 200.8	2/25/2025
119 Drinking Fountain	2/19/2025	4:53AM	N	<1.0	1.0	EPA 200.8	2/25/2025
213 Hall Water Cooler -1	2/19/2025	4:55AM	N	<1.0	1.0	EPA 200.8	2/25/2025
213 Hall Water Cooler -2	2/19/2025	4:56AM	N	<1.0	1.0	EPA 200.8	2/25/2025
140 Hall Drinking Fountain	2/19/2025	5:00AM	N	3.7	1.0	EPA 200.8	2/25/2025
141 Nurse Drinking Fountain	2/19/2025	5:04AM	N	4.4	1.0	EPA 200.8	2/25/2025
142 Drinking Fountain	2/19/2025	5:09AM	N	1.5	1.0	EPA 200.8	2/25/2025
216 Hall Water Cooler -1	2/19/2025	5:11AM	N	<1.0	1.0	EPA 200.8	2/25/2025
149 Drinking Fountain	2/19/2025	5:14AM	N	<1.0	1.0	EPA 200.8	2/25/2025
152 Drinking Fountain	2/19/2025	5:16AM	N	93.0	1.0	EPA 200.8	2/25/2025
150 Drinking Fountain	2/19/2025	5:18AM	N	<1.0	1.0	EPA 200.8	2/25/2025
151 Drinking Fountain	2/19/2025	5:21AM	N	<1.0	1.0	EPA 200.8	2/25/2025
217 Hall Drinking Fountain- 1	2/19/2025	5:23AM	N	2.4	1.0	EPA 200.8	2/25/2025
217 Hall Drinking Fountain - 2	2/19/2025	5:32AM	N	4.30	1.0	EPA 200.8	2/25/2025
217 Hall Drinking Fountain - 3	2/19/2025	5:34AM	N	9.8	1.0	EPA 200.8	2/25/2025